

## **TITLE 15 SEWER**

### **Chapter 15.10 GENERAL SEWER REGULATIONS**

#### **15.20.025 Prohibited Discharges**

(C) Solid or viscous substances in amounts which will cause obstruction of the flow in or to the sewage system resulting in interference [but in no case solids greater than one half inch [ $\frac{1}{2}$ "] or one and one quarter centimeters [1.25 cm] in any dimension.

(R) **Grease**, animal renderings or tissues, paunch manure, bones, hair, hides or fleshings, entrails, whole blood, feathers, ashes, cinders, sand, spent lime, stone or marble dusts, metal, glass, straw, shavings, grass clippings, rags, spent grains, spent hops, waste paper, wood, plastics, gasoline, tar asphalt residues, petroleum products, residues from refining or processing of fuel or lubricating oil, mud, glass grinding or polishing wastes.

#### **15.20.060 Pretreatment Facilities**

Users shall provide wastewater treatment to comply with Chapters 15.20 through 15.80 and shall achieve compliance within the time limitations specified by the EPA, the State, or the City, whichever is most stringent. **Any facilities required to pretreat wastewater to a level acceptable to the City shall be provided, operated, and maintained at the user's expense.** Detailed plans showing the pretreatment facilities and operating procedures shall be submitted to the City for review and construction shall not proceed until the plans are approved in writing by the City. The review of the plans and operating procedures does not relieve the user from the responsibility of modifying the facility as necessary to produce a discharge that complies with Chapters 15.20 through 15.80.

#### **15.20.070 Additional Pretreatment Measures**

**(3) Grease, oil, and sand interceptors shall be provided when, in the opinion of the City, they are necessary for the proper handling of wastewater containing excessive amounts of grease and oil, or sand, except that such interceptors shall not be required for residential users. All interception units shall be of type and capacity approved by the City and shall be located to be easily accessible for cleaning and inspection. Interceptors shall be inspected, cleaned, and repaired regularly, as needed, by the user at their expense.** All records for inspections, cleaning and repair must be maintained and readily available for review by City staff. Records should include third party cleaning manifests.